



**Maple Grove
13805 85th PI**

**Operation 1010: Abandon faulted wires.
Install by direct bore approx 100' of #6 AL
DX in 1 1/2" conduit. Terminate wires and
restore worksite to prior condition.**

Work Order Information	
Service Request # :	00000072970
Design Number :	ercd98
Designer/Planner ID :	Erickson, Darnor
Designer/Planner Name :	Erickson, Darnor
Designer/Planner Ph # :	
Manager Approval :	
Joint Utility	
E :	G :
T :	C :
Design Location	
Division :	Maple Grove
County :	Hennepin
City :	Maple Grove
Address :	
T :	119N R: 22W S: 15
Map # :	K52056 Permit
Electric	
Feeder :	
Phase :	BkupDevID:
Gas	
System :	Pressure :
Size :	Material :
Dead End :	
Work Order # :	000100643157
Date :	11/30/2017
Sketch :	# of # Sketch Data
Scale :	1" equals 100'
CONSTRUCTION USE ONLY	
<input type="checkbox"/>	NO CHANGES (BUILT AS DESIGNED)
<input type="checkbox"/>	CHANGES MADE AS INDICATED
<input type="checkbox"/>	(ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE)
RFID	
FOREMAN	DATE
TEAM LEADER	

DISCLAIMER: THERE ARE NO REPRESENTATIONS OR WARRANTIES (EXPRESS OR IMPLIED) ABOUT THE ACCURACY OF THIS PRINT. THIS PRINT IS PROVIDED WITH NO WARRANTIES TO PRINT COMPLETENESS, TIMELINESS, ACCURACY OF CONTENT OR USEFULNESS. STATE LAW REQUIRES ANYONE DIGGING, GRADING OR EXCAVATING TO OBTAIN A FIELD COPY OF ALL UTILITIES. THIS PRINT DOES NOT DISCHARGE THIS REQUIREMENT OR ANY OTHER REQUIREMENT. THE COMPANY AND ITS AGENTS ASSUME NO LIABILITY FOR THE RECIPIENT'S USE, OR ANY OTHER PARTIES' USE, OF THIS PRINT, INCLUDING THE RECIPIENT'S INTENDED PURPOSE IN USING THIS PRINT. THE RECIPIENT & ANY OTHER PARTY RECEIVING A COPY OF THIS PRINT ACKNOWLEDGES AND AGREES TO THIS DISCLAIMER. For All Field Locales Call 811