

WHEN BUTT FUSING TO EXISTING IN-SERVICE POLYETHYLENE, VISUALLY INSPECT FOR THE PRESENCE OF HYDROCARBON PERMEATION IMMEDIATELY AFTER REMOVING FUSION IRON. IF ANY BUBBLING IS IDENTIFIED ON THE HEATED SURFACE, DO NOT JOIN TO NEW PE PIPE. ALLOW TO COOL AND CUT THIS END OFF (12" LENGTH) AND SEND TO THE GOLDEN VALLEY LAB WITH STREET LOCATION AND W.O. #. COMPLETE TIE-IN/EXTENSION USING AN ELECTROFUSION COUPLING(S). DOCUMENT IN FIELD NOTES.

Project area cleared for internal impacts. Pipe being removed is unregulated for disposal if coating does not exist or is non-asbestos. Refer to CNP Construction and Service Manual CS-B-1.110, CS-B-1.330, and CS-B-1.100, for pipe to be abandoned.

CUSTOMER APPROVAL OF DESIGN I/C:

SIGNATURE: _____ DATE: _____


PRINTED NAME: _____

EMAIL: _____

Please review Center Point Energy design for installing Natural Gas to your facility. Verify the route of the Service Line and Meter Location on the building. If there is a conflict please contact the Designer or Sales Rep as shown in the Title Block.

WO# 89546343 I/C Install New Service Line-Plastic - CSV
 INSTALL: 4" X 1-1/4" IPS PE SVC TEE W/ 3/4" TAP
 INSTALL 325' OF 1-1/4" IPS PE CL-6 SVC LINE
 W/ 1-1/4" PE 5500 EFV (ASSEMBLY) OFF TEE
 W/ 3/4" MPT x 1/2" CTS ANODELESS RISER, W/SLEEVE
 SVC EQUIP# 64439634

WO# 89480398 I/C Install SmVol Gas Meter - CSV
 INSTALL 425TC ERT'D OSM (CL-6) (LOAD: 400 CFH)
 W/ 3/4" X 1" REG @ 2PSI W/ 3/16" ORIFICE
 MTR EQUIP# 15234685



CenterPoint Energy

PROPRIETARY AND CONFIDENTIAL

89546343

M52900 MAPLE GROVE

ONE CALL:
 Hennepin
 *SW12 T119/R22
 *SE11 T119/R22
 * = this Page

LEGEND:

—	ACTIVE		Interruptible
—	DESIGNED		Existing
—	PROPOSED		Normal
—	ABANDONED		Future
—	ABANDONED		Proposed

Address: 9565 ZACHARY LN N
Customer: CHRISTIAN BROTHERS AUTO

Contact Person: DAN WEIDNER
 Contact Phone: 281-675-6132
 Sales Rep: SHELLY HOUDE
 Sales Rep Phone: 320-808-8630
 Construction Hotline: 612-321-5310
 Curb Valve: No
 Copies to Corrosion: No
 Corrosion Approval: N/A
 Follow Internal Pipe Sampling Requirements? No
 Permits: COUNTY
 Requested Install Date: 04/21/2019

Approval: **SMY 3/25/19**

PROJECT DESCRIPTION:
CHRISTIAN BROTHERS AUTO

DESIGNER: Grant Dhein
 PHONE #: 612-321-5065
 DRAWN BY: Grant Dhein
 DESIGN DATE: 3/25/2019

Revised Print
 Destroy All Others
 Revision History
 Date:
 Description:
 Design Approval:

IC Services
 SCAN DATE: SHEET 1 OF 1

