


15236 96TH AVE N
 Feeder: ECL061/C/7.97 KVA
 -Replace only bad cable from xfrmer H7 to G7 & from G7 splice to xfrmer D7 splice to xfrmer F07 & from L.B.C (F07) to xfrmer K8.
 -Replace bad cable also from F08 to xfrmer J9
 Restorations



Kpatcha Toyisson
 651-265-7033

| Work Order Information | |
|------------------------|--------------------|
| Service Request # | : |
| Design Number | : 000000851102 |
| Designer/Planner ID | : 233215 |
| Designer/Planner Name | : Toyisson,Kpatcha |
| Designer/Planner Ph # | : (000) 000-0000 |
| Manager Approval | : |

| Joint Utility | |
|---------------|----|
| E: | G: |
| T: | C: |

| Design Location | |
|-----------------|---------------|
| Division | : Maple Grove |
| County | : Hennepin |
| City | : Maple Grove |
| Address | : |
| T: 119N | R: 22W S: 9 |
| Map # | : K52024 |
| Permit | : |

| Electric | |
|----------|--------------|
| Feeder: | Voltage: |
| Phase: | Bkup Dev ID: |

| Gas | |
|----------|--------------|
| System | : Pressure : |
| Size | : Material : |
| Dead End | : |

Work Order # :
 Date: 03/12/2019
 Sketch: # Of # Sketch Data
 Scale: 1" equals 125'



| CONSTRUCTION USE ONLY | |
|--------------------------|--|
| <input type="checkbox"/> | NO CHANGES (BUILT AS DESIGNED) |
| <input type="checkbox"/> | CHANGES MADE AS INDICATED (ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE) |

RFO _____
 FOREMAN _____ DATE _____
 TEAM LEADER _____

DISCLAIMER: THERE ARE NO REPRESENTATIONS OR WARRANTIES (EXPRESS OR IMPLIED) ABOUT THE ACCURACY OF THIS PRINT. THIS PRINT IS PROVIDED WITH NO CLAIM AS TO PRINT COMPLETENESS, TIMELINESS, ACCURACY OF CONTENT OR USEFULNESS. STATE LAW REQUIRES ANYONE DIGGING, GRADING OR EXCAVATING TO OBTAIN A PRIOR FIELD LOCATE OF ALL UTILITIES; THIS PRINT DOES NOT DISCHARGE THIS REQUIREMENT OR ANY OTHER REQUIREMENT. THE COMPANY AND ITS AFFILIATES ASSUME NO LEGAL RESPONSIBILITY OR LIABILITY FOR THE RECIPIENT'S USE (OR ANY OTHER PARTIES' USE) OF THE PRINT, INCLUDING THE RECIPIENT'S INTENDED PURPOSE IN USING THE PRINT. NO COMPANY EMPLOYEE OR OTHER PARTY HAS BEEN AUTHORIZED TO PROVIDE THIS PRINT FOR PLANNING OR ESTIMATING PURPOSES; RELY ON THIS PRINT AT YOUR OWN RISK. BY ACCEPTING THIS PRINT, THE RECIPIENT & ANY OTHER PARTY RECEIVING A COPY OF THE PRINT ACKNOWLEDGES AND AGREES TO THIS DISCLAIMER. For All Field Locates Call 811