

WO# 90602681 1/2" Install New Service Line-Plastic - CSV
 INSTALL: 4" X 1-1/4" IPS PE SVC TEE W/ 3/4" TAP
 INSTALL 500' OF 1-1/4" IPS PE CL-6 SVC LINE
 W/ 1-1/4" PE 5500 SERIES EFV OFF TEE
 W/ 1-1/4" MPT X 1-1/4" IPS ANODELESS RISER
 W/ BYPASS, W/SLEEVE
 SVC EQUIP# 64593164

WO# 90406531 1/2" Install MedVol Gas Meter - CSV
 INSTALL 3MTC ERTD OSM W/ BYPASS
 (CL-6) (LOAD: 3,000 CFH)
 @2PSI W/ 2" CS820R REGULATOR W/ 1/4" ORIFICE
 W/ 1" 289H RELIEF @3PSI
 MTR EQUIP# 15267479

CUSTOMER APPROVAL OF DESIGN I/C:

SIGNATURE: _____ DATE: _____
 PRINTED NAME: _____
 Please review the Center Point Energy design for installing Natural Gas to your facility.
 Verify the route of the Service Line and Meter Location on the building.
 If there is a conflict please contact the Designer or Sales Rep as shown in the Title Block.
 Before a natural gas service lines can be installed, you must clearly mark all privately-owned underground facilities including: septic tanks, drain fields, sewer lines, water wells, sprinkler systems, invisible fences, electric lines and pipelines.
 CenterPoint Energy and its representatives are not responsible for damage to these items if they are not clearly marked at time of installation.

When butt fusing to existing in-service polyethylene, visually inspect for the presence of hydrocarbon permeation immediately after removing fusion iron. If any bubbling is identified on the heated surface, do not join to new PE pipe. Allow to cool and cut this end off (12" length) and send to the Golden Valley Lab with street location and W.O. #. Complete tie-in/extension using an electrofusion coupling(s). Document in field notes.

Project area cleared for internal impacts. Pipe being removed is unregulated for disposal if coating does not exist or is non-asbestos. Refer to CNP Construction and Service Manual CS-B-1.110, CS-B-1.330, and CS-B-1.100, for pipe to be abandoned.



PROPRIETARY AND CONFIDENTIAL

90602681

M52900 MAPLE GROVE

ONE CALL:
 Hennepin
 *SW13 T119/R22
 * = this Page

LEGEND:

	ACTIVE		Interruptible
	DESIGNED		Existing
	PROPOSED		Normal
	ABANDONED		Future
	ABANDONED		Proposed

Address: 10950 85TH AVE N
 Customer: ARBOR LAKES CORPORATE CTR
 Contact Person: JEREMIAH CUNNINGHAM
 Contact Phone: 952-656-4439
 Sales Rep: MELISSA LISHER
 Sales Rep Phone: 612-861-8455
 Construction Hotline: 612-321-5310
 Curb Valve: No
 Copies to Corrosion: No
 Corrosion Approval: N/A
 Follow Internal Pipe Sampling Requirements? No
 Permits: CITY
 Requested Install Date: 08/03/2019
 Approval: **JGM 6/25/19**

PROJECT DESCRIPTION:
 ARBOR LAKES CORPORATE CTR

DESIGNER: Grant Dhein
 PHONE #: 612-321-5065
 DRAWN BY: Grant Dhein
 DESIGN DATE: 6/25/2019

Revised Print
 Destroy All Others
 Revision History
 Date:
 Design Approval:
 Description:

IC Services
 SCAN DATE:
 1" = 120'
 SHEET 1 OF 1

