

SERVICE WO# 79952040
 INSTALL: 2" X 1-1/4" IPS PE SVC TEE W/ 3/4"
 TAP. INSTALL 180' OF 1-1/4" IPS PE CL-6 SVC
 LINE W/ 1-1/4" MPT x 1-1/4" IPS ANODELESS
 RISER W/ BYPASS, W/SLEEVE.
 TAP LOC: 500' NCL ARBOR LAKES PKWY
 SERVICE EQUIP# 60632816

METERSET WO# 79934384
 METER M/I WO# 79952038
 INSTALL 5MTC OUTSIDE METERSET (CL-6) (LOAD: 5000cfh) ON
 TEMP HEAT BOARD @5PSI W/ 2" B34R REGULATOR W/ 7/8"
 ORIFICE W/ 1" 289H RELIEF @6PSI ON A 1-1/4" MPT x 1-1/4" IPS
 ANODELESS RISER W/ BYPASS. RIGHT TO LEFT FLOW.
 MTRSET EQUIP# 14888097

CUSTOMER APPROVAL OF DESIGN NEW I/C:
 SIGNATURE: _____ DATE: _____
 PRINTED NAME: _____
 EMAIL: _____
 Please review Center Point Energy design for
 installing Natural Gas to your facility. Verify the
 route of the Service Line and Meter Location on
 the building. If there is a conflict please contact the
 Designer or Sales Rep as shown in the Title Block.



PROPRIETARY AND CONFIDENTIAL

79952040
 M52900 MAPLE GROVE

ONE CALL:
 Hennepin
 *SE23 T119/R22
 * = this Page

- LEGEND:
- ACTIVE
 - DESIGNED
 - - - PROPOSED
 - - - ABANDONED
 - A ABANDONED
 - Interruptible
 - Existing
 - Normal
 - Future
 - Proposed

Address: 11550 Arbor Lakes Pkwy
 Customer: Village Arbor Lks Rsrvt
 Contact Person: Don Romer
 Contact Phone: 952-448-6225
 Sales Rep: Cherie Monson
 Sales Rep Phone: 612-910-1225
 Construction Hotline: 612-321-5310
 Copies To Pipeline Integrity: No
 Customer Service Valve: No
 Copies to Corrosion: No
 Corrosion Approval: N/A
 Follow Internal Pipe Sampling
 Requirements? No
 Permits: Yes - city
 Requested Install Date: 11/13/16
 Maps: 4-23
 Approval: *Ben Romer*

PROJECT DESCRIPTION:
 VILLAGE ARBOR LKS RSV TEMP

DESIGNER: Wendy Seidl
 PHONE #: 612-321-5476
 DRAWN BY: Wendy Seidl
 DESIGN DATE: 10/20/2016

Revised Print
 Destroy All Others
 Revision History
 Date:
 Description:
 Design Approval:

IC Services
 SCAN DATE: 11/16/16
 1" : 83'
 SHEET 1 OF 1

10/20/2016 1:22:37 PM DESIGNER EXPRESS DESIGN