

**REPLACE RUSTED OUT PMH-9 "H" WITH
NEW 3PH FUSED LBC "K52064W01".**

ECK062- 13.8KV (1/1)


Remove existing PMH-9 "H". This eliminates 300A disconnect switches K52064X03 & K52064X04 along with 50E fuse K264 L70.

Install new 3PH fused LBC "K52064W01".
Fuse C PH with 65E fuse - POI K52064F05
Fuse B PH with 65E fuse - POI K52064F04

Restoration

Restore grassy area at LBC location.

Designer-
John Pfothenauer
736-493-1876
612-963-3804 cell



Work Order Information	
Service Request #	:
Design Number	: 00000910150
Designer/Planner ID	: pftj01
Designer/Planner Name	: Pfothenauer, John
Designer/Planner Ph #	: (763) 493-1876
Manager Approval	:

Joint Utility	
E:	G:
T:	C:

Design Location	
Division	: Maple Grove
County	: Hennepin
City	: Maple Grove
Address	: 15593 Shadow Creek
T: 119N	R: 22W S: 21
Map #	: K52064
Permit	:

Electric	
Feeder:	ECK062
Voltage:	13.8KV
Phase:	ABC
Bkup Dev ID:	:

Gas	
System	: Pressure
Size	: Material
Dead End	:

Work Order #	:
Date:	01/09/2020
Sketch:	1 Of 1 Sketch Data
Scale:	1" equals 100'

CONSTRUCTION USE ONLY	
<input type="checkbox"/>	NO CHANGES (BUILT AS DESIGNED)
<input type="checkbox"/>	CHANGES MADE AS INDICATED (ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE)
RFO	_____
FOREMAN	_____ DATE _____
TEAM LEADER	_____

DISCLAIMER: THERE ARE NO REPRESENTATIONS OR WARRANTIES (EXPRESS OR IMPLIED) ABOUT THE ACCURACY OF THIS PRINT. THIS PRINT IS PROVIDED WITH NO CLAIM AS TO PRINT COMPLETENESS, TIMELINESS, ACCURACY OF CONTENT OR USEFULNESS. STATE LAW REQUIRES ANYONE DIGGING, GRADING OR EXCAVATING TO OBTAIN A PRIOR FIELD LOCATE OF ALL UTILITIES; THIS PRINT DOES NOT DISCHARGE THIS REQUIREMENT OR ANY OTHER REQUIREMENT. THE COMPANY AND ITS AFFILIATES ASSUME NO LEGAL RESPONSIBILITY OR LIABILITY FOR THE RECIPIENT'S USE (OR ANY OTHER PARTIES' USE) OF THE PRINT, INCLUDING THE RECIPIENT'S INTENDED PURPOSE IN USING THE PRINT. NO COMPANY EMPLOYEE OR OTHER PARTY HAS BEEN AUTHORIZED TO PROVIDE THIS PRINT FOR PLANNING OR ESTIMATING PURPOSES; RELY ON THIS PRINT AT YOUR OWN RISK. BY ACCEPTING THIS PRINT, THE RECIPIENT & ANY OTHER PARTY RECEIVING A COPY OF THE PRINT ACKNOWLEDGES AND AGREES TO THIS DISCLAIMER. For All Field Locates Call 811