

NOTE PRIMARY IN TELEPHONE TRENCH
SEC 4' NUMBER OF PRIMARY

17002 WEAVER LAKE DR
POI: K252 P03
ECK082/C/7.9KV


TASK 1: DIRECTIONAL BORE
BORE IN 205' OF 1/0 AL UG TRIPLEX CABLE P1 TO P2

TASK 2: TERMINATION
TERMINATE AT P1 AND P2

TASK 3: RESTORATION

TASK 4: REMOVE HOUSE-TO-HOUSE TEMP

NOTE: ABANDON EXISTING SVC CABLE IN PLACE
REPLACE PADLOCK ON TRANSFORMER
REMOVE LANDSCAPE ROCK AT METER
REMOVE LANDSCAPE AT TRANSFORMER



Work Order Information	
Service Request #	:
Design Number	: 00000935915
Designer/Planner ID	: 243322
Designer/Planner Name	: Grosko, Deborah
Designer/Planner Ph #	: (816) 414-1113
Manager Approval	:

Joint Utility	
E:	G:
T:	C:



Design Location	
Division	: Maple Grove
County	: Hennepin
City	: Maple Grove
Address	: 17002 Weaver Lake Dr
T: 119N	R: 22W S: 17
Map #	: K52052 Permit : Maple Grove

Electric	
Feeder: ECK082	Voltage: 7.9kV
Phase: C	Bkup Dev ID:

Gas	
System	: Pressure
Size	: Material
Dead End	:

Work Order # : 00000104526084

Date: 04/07/2020
Sketch: 1 Of 1 Sketch Data
Scale: 1" equals 84'



CONSTRUCTION USE ONLY

NO CHANGES (BUILT AS DESIGNED)
 CHANGES MADE AS INDICATED
(ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE)

RFO _____
FOREMAN _____ DATE _____
TEAM LEADER _____

DISCLAIMER: For All Field Locates Call 811
CLAIM AS TO PRINT COMPLETENESS, TIME, FITNESS, ACCURACY OF CONTENT OR USEFULNESS. STATE LAW REQUIRES ANYONE DIGGING OR EXCAVATING TO OBTAIN A
SUME NO LEGAL RESPONSIBILITY OR LIABILITY FOR THE RECIPIENT'S USE (OR ANY OTHER PARTIES' USE) OF THE PRINT, INCLUDING THE RECIPIENT'S INTENDED PURPOSE IN
THIS PRINT AT YOUR OWN RISK. BY ACCEPTING THIS PRINT, THE RECIPIENT & ANY OTHER PARTY RECEIVING A COPY OF THE PRINT ACKNOWLEDGES AND AGREES TO THIS