

PROPRIETARY AND CONFIDENTIAL

**77675044**  
M52900 MAPLE GROVE

ONE CALL:  
Hennepin  
\*SW23 T119/R22  
\* = this Page



**LEGEND:**  
 ACTIVE  
 DESIGNED  
 PROPOSED  
 ABANDONED  
 ABANDONED

Interruptible  
 Existing  
 Normal  
 Future  
 Proposed

Address: 11901 CENTRAL PARKWAY  
 Customer: SKYE AT ARBOR LAKES 2  
 Contact Person: JASON VANASSE  
 Contact Phone: 952-567-9238  
 Sales Rep: CHERIE MONSON  
 Sales Rep Phone: 612-321-5435  
 Construction Hotline: 612-321-5310  
 Copies To Pipeline Integrity: No  
 Customer Service Valve: No  
 Copies to Corrosion: No  
 Corrosion Approval:  
 Follow Internal Pipe Sampling Requirements? No  
 GFIP#: NA  
 Permits: CITY  
 Requested Install Date: 06/01/2016  
 Maps:

**PROJECT DESCRIPTION:**  
SKYE

DESIGNER: Tracie Killion  
 PHONE #: 612-321-5559  
 DRAWN BY: Tracie Killion  
 DESIGN DATE: 3/31/2016

Revised Print  
 Destroy All Others  
 Revision History  
 Date:  
 Description:  
 Design Approval:

IC Services  
 SCAN DATE: 1" : 80'  
 SHEET 1 OF 1

Install New Service Line - Plastic W/O#77677334 DROP 6  
 CONTACT: JASON VANASSE 952-261-6017  
 INSTALL: 2" X 1-1/4" IPS PE2406/2708 SVC TEE W/ 3/4" TAP  
 INSTALL 90' OF 1 1/4" IPS PE2406/2708 CL-6 SERVICE LINE  
 W/ 1 1/4" MPT x 1 1/4" IPS ANODELESS RISER W/ BYPASS, W/SLEEVE  
 COORDINATE METER WORK WITH STEVE NORDLUND  
 CITY PERMIT REQUIRED  
 SVC EQUIP#60401427

Install New Service-Plastic - CURB SVC LINE W/O#77948028  
 CONTACT: JASON VANASSE 952-261-6017  
 INSTALL: 2" X 1-1/4" IPS PE2406/2708 SVC TEE W/ 3/4" TAP  
 INSTALL 65' OF 1 1/4" IPS PE2406/2708 CL-6 SERVICE LINE  
 INSTALL 1 1/4" PE END CAP W/ MARKER BALL, W/PIPELINE MARKER  
 INSTALL ACROSS ROAD AND OUT OF RIGHT OF WAY  
 SVC EQUIP#60401425

Install New Service Line - Plastic W/O#77499482 DROP 1  
 INSTALL: 4" X 1-1/4" IPS PE2406/2708 SVC TEE W/ 3/4" TAP  
 INSTALL 40' OF 1 1/4" IPS PE2406/2708 CL-6 SERVICE LINE  
 W/ 1 1/4" MPT x 1 1/4" IPS ANODELESS RISER W/ BYPASS, W/SLEEVE  
 COORDINATE WITH JIM EASON 62-363-9692  
 NO PERMIT NEEDED  
 SVC EQUIP#60401417

Repair Service Line-Plastic W/O#77675044 DROP 7  
 CONTACT: JASON VANASSE 952-261-6017  
 EXTEND EXISTING 1 1/4" PE SVC LINE TO NEW METER LOCATION  
 INSTALL 1 1/4" MPT x 1 1/4" IPS ANODELESS RISER W/ BYPASS, W/SLEEVE  
 COORDINATE WITH STEVE NORDLUND 612-363-6701  
 SVC EQUIP#60119675

DESIGNER EXPRESS DESIGN 4/15/2016 3:05:56 PM

