

Dead-end the primary & add 30T fuse at existing pole located on the east side of Pilgrim Ln N to support coordination behind 1PH recloser R070100L.

POI- L52021F10 TRUCK ACCESS


PG. 2
10050 94TH AVE N, MG

UPDATE FUSE COORDINATION BEHIND 1PH RECLOSER R070100L.

OSS073 - 7.9KV (1/1)

REFERRAL #54751588

DESIGNER-
 John Pfothenauer
 612-963-3804



| Work Order Information | |
|------------------------|---------------------|
| Service Request # | : |
| Design Number | : 000000958418 |
| Designer/Planner ID | : pftj01 |
| Designer/Planner Name | : Pfothenauer, John |
| Designer/Planner Ph # | : (763) 493-1876 |
| Manager Approval | : |

| Joint Utility | |
|---------------|----|
| E: | G: |
| T: | C: |

| Design Location | |
|-----------------|-------------------|
| Division | : Maple Grove |
| County | : HENNEPIN |
| City | : MAPLE GROVE |
| Address | : 9624 93RD AVE N |
| T: 119N | R: 22W S: 12 |
| Map # | : L52021 |
| Permit | : |

| Electric | |
|----------------|-------------------|
| Feeder: OSS073 | Voltage: 7970 KVA |
| Phase: A | Bkup Dev ID: |


| Gas | |
|----------|------------|
| System | : Pressure |
| Size | : Material |
| Dead End | : |

Work Order # : **105087584**

Date: 08/14/2020

Sketch: 1 Of 1 Sketch Data

Scale: 1" equals 100'



| CONSTRUCTION USE ONLY | |
|--------------------------|---------------------------------------------------------------------------------------|
| <input type="checkbox"/> | NO CHANGES (BUILT AS DESIGNED) |
| <input type="checkbox"/> | CHANGES MADE AS INDICATED (ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE) |

RFO _____

FOREMAN _____ DATE _____

TEAM LEADER _____

DISCLAIMER: THERE ARE NO REPRESENTATIONS OR WARRANTIES (EXPRESS OR IMPLIED) ABOUT THE ACCURACY OF THIS PRINT. THIS PRINT IS PROVIDED WITH NO CLAIM AS TO PRINT COMPLETENESS, TIMELINESS, ACCURACY OF CONTENT OR USEFULNESS. STATE LAW REQUIRES ANYONE DIGGING, GRADING OR EXCAVATING TO OBTAIN A PRIOR FIELD LOCATE OF ALL UTILITIES. THIS PRINT DOES NOT DISCHARGE THIS REQUIREMENT OR ANY OTHER REQUIREMENT. THE COMPANY AND ITS AFFILIATES ASSUME NO LEGAL RESPONSIBILITY OR LIABILITY FOR THE RECIPIENT'S USE (OR ANY OTHER PARTIES' USE) OF THE PRINT, INCLUDING THE RECIPIENT'S INTENDED PURPOSE IN USING THE PRINT. NO COMPANY EMPLOYEE OR OTHER PARTY HAS BEEN AUTHORIZED TO PROVIDE THIS PRINT FOR PLANNING OR ESTIMATING PURPOSES; RELY ON THIS PRINT AT YOUR OWN RISK. BY ACCEPTING THIS PRINT, THE RECIPIENT & ANY OTHER PARTY RECEIVING A COPY OF THE PRINT ACKNOWLEDGES AND AGREES TO THIS DISCLAIMER. For All Field Locates Call 811

THIS DOCUMENT IS XCEL ENERGY CONFIDENTIALS AND PROPRIETARY INFORMATION AND MAY NOT BE REPRODUCED IN WHOLE, OR IN PART, NOR MAY ANY OF THE INFORMATION CONTAINED HEREIN BE DISCLOSED WITHOUT THE CONSENT OF XCEL ENERGY. CONFIDENTIALS AND PROPRIETARY INFORMATION © 2019 XCEL ENERGY INC. | XCEL ENERGY IS REGISTERED TRADEMARK OF XCEL ENERGY INC