

When butt fusing to existing in-service polyethylene, visually inspect for the presence of hydrocarbon permeation immediately after removing fusion iron. If any bubbling is identified on the heated surface, do not join to new PE pipe. Allow to cool and cut this end off (12" length) and send to the Golden Valley Lab with street location and W.O. #. Complete tie-in/extension using an electrofusion coupling(s). Document in field notes.

Project area cleared for internal impacts. Pipe being removed is unregulated for disposal if coating does not exist or is non-asbestos. Refer to CNP Construction and Service Manual CS-B-1.110, CS-B-1.330, and CS-B-1.100, for pipe to be abandoned.

WO# 96187870 Install New Service Line - Plastic - CSV
 INSTALL: 6" X 1-1/4" IPS PE2406/2708 SVC TEE W/ 3/4" TAP
 INSTALL 1 1/4" POLY VALVE JUST OFF OF TEE
 FILL OUT EMP FORM 130 VALVE EQ 15451656
 INSTALL 100' OF 1 1/4" IPS PE2406/2708 CL-6 SERVICE LINE
 W/ 1 1/4" MPT x 1 1/4" IPS ANODELESS RISER W/ BYPASS, W/SLEEVE
 SVC EQUIP 68229343

WO# 96187724 Move-in Medium Meter Install - Original - CSV
 INSTALL 5MTC ERT'D METERSET TEMP HEAT (CL-6 5,600 CFH)
 @5PSI W/2" CS820 REGULATOR W/ 1/2" ORIFICE W/ 1" 289H RELIEF @7PSI
 INSTALL 2" INSULATED UNION CUSTOMER VALVE BALL VALVE ON OUTLET
 MTR EQUIP 15451657



PROPRIETARY AND CONFIDENTIAL

96187870
 M52900 MAPLE GROVE

ONE CALL:
 Hennepin
 *NE9 T119/R22
 * = this Page

LEGEND:

	ACTIVE		Interruptible
	DESIGNED		Existing
	PROPOSED		Normal
	ABANDONED		Future
	ABANDONED		Proposed

Address: 14800 99TH AVE N
Customer: 99TH AVE APTS
Contact Person: TYLER RIVARD
Contact Phone: 701-429-8072
Sales Rep: SHELLY HOUDE
Sales Rep Phone: 763-785-5428
Construction Hotline: 612-321-5310
Copies To Pipeline Integrity: No
Curb Valve: Yes
Copies to Corrosion: No
Corrosion Approval: NA
Follow Internal Pipe Sampling Requirements? No
GFIP#: N/A
Permits: CITY
Requested Install Date: 12/13/2020

Approval: _____

PROJECT DESCRIPTION:
 99TH AVE N

DESIGNER: Stacie Yerks
 PHONE #: 612-321-5279
 DRAWN BY: Stacie Yerks
 DESIGN DATE: 11/23/2020

Revised Print
 Destroy All Others
 Revision History
 Date:
 Description:
 Design Approval:

IC Services 1" : 150'
 SCAN DATE: SHEET 1 OF 1

DESIGNER EXPRESS DESIGN

11/23/2020 1:50:50 PM

CUSTOMER APPROVAL OF DESIGN I/C:
 SIGNATURE: _____
 PRINTED NAME: _____ DATE: _____
 Please review Center Point Energy design for installing Natural Gas to your facility. Verify the route of the Service Line and Meter Location on the building. If there is a conflict please contact the Designer or Sales Rep as shown in the Title Block. Before a natural gas service lines can be installed, you must clearly mark all privately-owned underground facilities including: septic tanks, drain fields, sewer lines, water wells, sprinkler systems, invisible fences, electric lines and pipelines. CenterPoint Energy and its representatives are not responsible for damage to these items if they are not clearly marked at time of installation.

