

CUSTOMER APPROVAL OF DESIGN I/C:
 SIGNATURE: _____
 PRINTED NAME: _____ DATE: _____

Please review CenterPoint Energy design for installing Natural Gas to your facility. Verify the route of the Service Line and Meter Location on the building. If there is a conflict, please contact the Designer or Sales Rep as shown in the Title Block. Before a natural gas service line can be installed, you must clearly mark all privately-owned underground facilities including: septic tanks, drain fields, sewer lines, water wells, sprinkler systems, invisible fences, electric lines and pipelines. CenterPoint Energy and its representatives are not responsible for damage to these items if they are not clearly marked at time of installation.

Project area cleared for internal impacts. Pipe being removed is unregulated for disposal if coating does not exist or is non-asbestos. Refer to CNP Construction and Service Manual CS-B-1.110, CS-B-1.330, and CS-B-1.100, for pipe to be abandoned.



M/I METER WO# 96632363
 INSTALL a 630TC OUTSIDE METERSET (CL-6) (LOAD: 1085cfh) with a 3/4" 1813C REGULATOR at 2PSI with a 3/16" ORIFICE. NO RELIEF REQUIRED.
 HANG METER ON A TEMP HEAT BOARD.
 METERSET EQUIP# 15460381
 METER TO BE MOVED TO PERMANENT LOCATION ON BUILDING IN THE FUTURE - NO CHANGES TO THE METERSET WILL BE NEEDED

SERVICE WO# 96564289
 INSTALL a 6" X 1-1/4" IPS PE SVC TEE with a .80" TAP.
 INSTALL a 2" IPS EFV - 5500 SERIES 1-1/4" ASSEMBLY IN BLVD.
 INSTALL 145' of 1-1/4" IPS PE, CL-6 SVC LINE with a 1-1/4" MPT x 1-1/4" IPS ANODELESS RISER, with BYPASS, with SLEEVE.
 HANG METER ON A TEMP HEAT BOARD.
 SERVICE EQUIP# 68270161

NOTE: BORE ALL PAVED STREETS AND DRIVEWAYS

Minimum depth requirements for pneuma-gopher crossings of state highways and county roads is 60".
 Minimum depth requirements for pneuma-gopher crossings of city streets and township roads is 48".
 Minimum depth for parallel installations on state highways and county roads is 36".
 Minimum depth for parallel installations on city streets and township roads is 30".
 All steel pipe welds to be coated with 2 part epoxy.



PROPRIETARY AND CONFIDENTIAL

96564289
 M52900 MAPLE GROVE
 ONE CALL:
 Hennepin
 *SW30 T119/R22
 *= this Page

LEGEND:

- ACTIVE
- DESIGNED
- PROPOSED
- ABANDONED
- A ABANDONED

- Interruptible
- Existing
- Normal
- Future
- Proposed

Address: 18655 73rd Ave N
 Customer: New Creations
 Contact Person: Dan Slinde
 Contact Phone: 952-200-4769
 Sales Rep: Jack Miller
 Sales Rep Phone: 763-785-5432
 Construction Hotline: 612-321-5310
 Copies To Pipeline Integrity: No
 Curb Valve: No
 Copies to Corrosion: No
 Corrosion Approval: N/A
 Follow Internal Pipe Sampling Requirements? No
 GFIP#: N/A
 Permits: Yes - Hennepin County
 Requested Install Date: 01/24/2021

Approval: _____

PROJECT DESCRIPTION:
 NEW CREATIONS MAPLE GROVE

DESIGNER: TJ Dehne
PHONE #: 612-321-5426
DRAWN BY: TJ Dehne
DESIGN DATE: 1/6/2021

Revised Print
 Destroy All Others
 Revision History
 Date:
 Description:
 Design Approval:

IC Services
 SCAN DATE: 1" : 50'
 SHEET 1 OF 1

DESIGNER EXPRESS DESIGN
 1/6/2021 9:13:27 AM

