


CUSTOMER APPROVAL OF DESIGN I/C:  
 SIGNATURE: \_\_\_\_\_  
 PRINTED NAME: \_\_\_\_\_ DATE: \_\_\_\_\_

Please review CenterPoint Energy design for installing Natural Gas to your facility. Verify the route of the Service Line and Meter Location on the building. If there is a conflict, please contact the Designer or Sales Rep as shown in the Title Block. Before a natural gas service line can be installed, you must clearly mark all privately-owned underground facilities including: septic tanks, drain fields, sewer lines, water wells, sprinkler systems, invisible fences, electric lines and pipelines. CenterPoint Energy and its representatives are not responsible for damage to these items if they are not clearly marked at time of installation.

Project area cleared for internal impacts. Pipe being removed is unregulated for disposal if coating does not exist or is non-asbestos. Refer to CNP Construction and Service Manual CS-B-1.110, CS-B-1.330, and CS-B-1.100, for pipe to be abandoned.

SERVICE WO# 98969845  
 INSTALL a 2" X 2" IPS PE SVC TEE with a 1-1/2" TAP.  
 INSTALL a 2" IPS EFV - 10000 SERIES IN BLVD.  
 INSTALL 550' of 2" IPS PE, CL-6 SVC LINE with a 1-1/4" MPT x 1-1/4" IPS ANODELESS RISER.  
 SERVICE EQUIP# 69753279

M/I METER WO# 98969137  
 INSTALL a 3MID OUTSIDE METERSSET for TEMP HEAT ONLY (CL-6) (LOAD: 12000 cfm), with a 2" SCREWED OUTLET, LEFT TO RIGHT FLOW, with a 2" CL-38-IM-2 REGULATOR at 10PSI with a 5/8" ORIFICE and a 1" 289H RELIEF at 11PSI.  
 METERSSET EQUIP# 15617606



PROPRIETARY AND CONFIDENTIAL

**98969845**  
 M52900 MAPLE GROVE  
 ONE CALL:  
 Hennepin  
 \*NE21 T119/R22  
 \* = this Page

**LEGEND:**

- ACTIVE
- DESIGNED
- PROPOSED
- ABANDONED
- A ABANDONED

- Interruptible
- Existing
- Normal
- Future
- Proposed

Address: 4 Scimed Pl  
 Customer: Boston Scientific  
 Contact Person: Dustin Lane  
 Contact Phone: 612-490-1376  
 Sales Rep: Perry Schmidt  
 Sales Rep Phone: 612-749-7462  
 Construction Hotline: 612-321-5310  
 Copies To Pipeline Integrity: No  
 Curb Valve: No  
 Copies to Corrosion: No  
 Corrosion Approval: N/A  
 Follow Internal Pipe Sampling Requirements? No  
 GFIP#: N/A  
 Permits: Yes - City Of Maple Grove  
 Requested Install Date: 08/01/2021  
 Approval: Cameron Victor 7-9-2021

**PROJECT DESCRIPTION:**  
 BOSTON SCIENTIFIC  
 WL4 BLDG TEMP HEAT

DESIGNER: TJ Dehne  
 PHONE #: 612-321-5426  
 DRAWN BY: TJ Dehne  
 DESIGN DATE: 7/9/2021

Revised Print  
 Destroy All Others  
 Revision History  
 Date:  
 Description:  
 Design Approval:

IC Services  
 SCAN DATE: 1" : 80'  
 SHEET 1 OF 1

7/9/2021 12:36:37 PM DESIGNER EXPRESS DESIGN

