

8303 OAKVIEW COURT N
 ID: 37086528
 POI: K267 X03
 ECK063/A/7.9KV

TASK 1: DIRECTIONAL BORE
 BORE IN 55' OF 350 TRIPLEX CABLE P1 TO P2

TASK 2: INSTALL NEW SECONDARY PEDESTAL ON LOT LINE OF 8329/8303

TASK 3: TERMINATION
 TERMINATE AT P1 AND P2

TASK 4: RESTORATION

TASK 5: REMOVE TEMP SERVICE

NOTE: ABANDON EXISTING SVC CABLE IN PLACE
REPLACE PADLOCK ON TRANSFORMER AND SECONDARY PEDESTAL



Work Order Information	
Service Request #	: 000013654463
Design Number	: 00000117437
Designer/Planner ID	: 249322
Designer/Planner Name	: DEBORAH GROSKO
Designer/Planner Ph #	: (816) 414-1113
Manager Approval	: _____


Joint Utility	
E:	G:
T:	C:

Design Location	
Division	: Maple Grove
County	: Hennepin
City	: Maple Grove
Address	: 8303 Oakview Court N
T: 119N	R: 22W S: 22
Map #	: K52067 Permit : Maple Grove

Electric	
Feeder: ECK063	Voltage: 7.9KV
Phase: A	Bkup Dev ID:

Gas	
System	: Pressure :
Size	: Material :
Dead End	:

Work Order #: 00000109278617
 Date: 03/24/2023
 Sketch: 1 Of 1 Sketch Data
 Scale: 1" equals 83'



CONSTRUCTION USE ONLY

NO CHANGES (BUILT AS DESIGNED)
 CHANGES MADE AS INDICATED
 (ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE)

RFO: _____
 FOREMAN: _____ DATE: _____
 TEAM LEADER: _____

THIS DOCUMENT IS XCEL ENERGY CONFIDENTIALS AND PROPRIETARY INFORMATION AND MAY NOT BE REPRODUCED IN WHOLE, OR IN PART, NOR MAY ANY OF THE INFORMATION CONTAINED HEREIN BE DISCLOSED WITHOUT THE CONSENT OF XCEL ENERGY. CONFIDENTIALS AND PROPRIETARY INFORMATION © 2019 XCEL ENERGY INC. | XCEL ENERGY IS REGISTERED TRADEMARK OF XCEL ENERGY INC.