



MAIN ST  
100'

3" TR CL-6 (A45271999)

12745

12575

CUSTOMER APPROVAL OF DESIGN I/C:

SIGNATURE: \_\_\_\_\_

PRINTED NAME: \_\_\_\_\_

DATE: \_\_\_\_\_

Please review Center Point Energy design for installing Natural Gas to your facility. Verify the route of the Service Line and Meter Location on the building. If there is a conflict please contact the Designer or Sales Rep as shown in the Title Block. Before natural gas service lines can be installed, you must clearly mark all privately-owned underground facilities including: septic tanks, drain fields, sewer lines, water wells, sprinkler systems, invisible fences, electric lines and pipelines. CenterPoint Energy and its representatives are not responsible for damage to these items if they are not clearly marked at time of installation.



**M/I METER WO# 108465591**

**INSTALL a 425TC OUTSIDE METERSET with a 3/4" x 1" 1813C REGULATOR at CL-6 to 2 PSI with a 3/16" ORIFICE (LOAD: 479cfh). METERSET EQUIP# 15962717**

**SERVICE WO# 108465594**

**INSTALL a 3" x 1-1/4" IPS PE SVC TEE with a .80" TAP  
INSTALL a 2" IPS EFV - 5500 SERIES 1-1/4" ASSEMBLY in the BLVD.  
INSTALL 150' of 1-1/4" IPS PE CL-6 SVC LINE with a 3/4" MPT x 1/2" CTS PE ANODELESS RISER, with SLEEVE.  
SERVICE EQUIP# 71517681**



PROPRIETARY AND CONFIDENTIAL

**108465594**

M52900 MAPLE GROVE

**LEGEND:**

- IN SERVICE
- PROPOSED
- PROPOSED ABANDONED
- ABANDONED
- Interruptible
- Existing
- Normal
- Future
- Proposed

Address: 12575 ELM CREEK BLVD N  
Customer: MAPLE GROVE PET HOSPITAL

Contact Person: Joe Santiago  
Contact Phone: 847-257-9770  
Sales Rep: Jason Kocke  
Sales Rep Phone: 612-258-4327  
Construction Hotline: 612-321-5310  
Restoration Hotline: 612-321-5042  
Copies To Pipeline Integrity: No  
Curb Valve: No  
Copies to Corrosion: No  
Corrosion Approval: N/A  
Follow Internal Pipe Sampling Requirements? No  
Job Briefing Required? No  
GFIP#: N/A  
Permits: Yes - City Of Maple Grove  
Requested Install Date: 08/14/2023

Approval:   
Tracie Killian

PROJECT DESCRIPTION:  
MAPLE GROVE PET HOSPITAL

DESIGNER: SHANNON MROZEK  
PHONE#: 612-210-6971  
DRAWN BY: SHANNON MROZEK  
DESIGN DATE: 07/19/2023

Revised Print  
Destroy All Others  
Revision History  
Date:  
Description:  
Design Approval:

SCAN DATE: \_\_\_\_\_ SCALE: 1"=60'  
SHEET 1 OF 1