



113258034

M52900 MAPLE GROVE

MGC#24-76246

LEGEND:

- IN SERVICE
- PROPOSED
- PROPOSED ABANDONED
- A ABANDONED
- Interruptible
- Existing
- Normal
- Future
- Proposed



NOTE: BORE ALL PAVED STREETS AND DRIVEWAYS
 Minimum depth requirements for crossings of state highways and county roads is 60". Minimum depth requirements for crossings of city streets and township roads is 48".
 Minimum depth for parallel installations on state highways and county roads is 36". Minimum depth for parallel installations on city streets and township roads is 30". All steel pipe welds to be coated with 2 part epoxy.

M/I METER WO# 113258033
 INSTALL a 250TC OUTSIDE METERSET with a 3/4" x 1" B42R REGULATOR at CL-6 to 7" W.C. with a 1/8" x 3/16" ORIFICE (LOAD: 120cfh).
 METERSSET EQUIP# 16119209

SERVICE WO# 113258034
 INSTALL a 2" x 1-1/4" IPS PE SVC TEE with a .80" TAP
 INSTALL a 2" IPS EFV - 5500 SERIES 1-1/4" ASSEMBLY in the BLVD.
 INSTALL 260' of 1-1/4" IPS PE CL-6 SVC LINE with a 3/4" MPT x 1/2" CTS PE ANODELESS RISER, with SLEEVE.
 SERVICE EQUIP# 77171364

CUSTOMER APPROVAL OF DESIGN

SIGNATURE: _____
 PRINTED NAME: _____ DATE: _____

Please review Center Point Energy design for installing Natural Gas to your facility. Verify the route of the Service Line and Meter Location on the building. If there is a conflict please contact the Designer or Sales Rep as shown in the Title Block. Before natural gas service lines can be installed, you must clearly mark all privately-owned underground facilities including: septic tanks, drain fields, sewer lines, water wells, sprinkler systems, invisible fences, electric lines and pipelines. CenterPoint Energy and its representatives are not responsible for damage to these items if they are not clearly marked at time of installation.

CUSTOMER APPROVAL SITE MEETING

SIGNATURE: _____
 PRINTED NAME: _____
 PHONE NUMBER: _____ DATE: _____

The site is ready for gas install and is within 6" of final grade. Any and all private crossings have been clearly marked on site. I acknowledge that any alterations after the gas line is installed will be at **Builder's/Owner's expense**. The final service depth to be 18" - 24" below grade.

Address: 7015 ALVARADO LN N
 Customer: TOPLINE FINANCIAL CREDIT UNION
 Contact Person: Chris Delay
 Contact Phone: 414-727-4380
 Sales Rep: Jason Kocke
 Sales Rep Phone: 612-258-4327
 Construction Hotline: 612-321-5310
 Restoration Hotline: 612-321-5042
 Copies To Pipeline Integrity: No
 Curb Valve: No
 Copies to Corrosion: No
 Corrosion Approval: N/A
 Follow Internal Pipe Sampling Requirements? No
 Job Briefing Required? No
 GFIP#: N/A
 Permits: Yes - City Of Maple Grove
 Requested Install Date: 09/30/2024
 Approval: *Tracie Killion*

PROJECT DESCRIPTION:
 TOPLINE FINANCIAL CREDIT UNION

DESIGNER: SHANNON MROZEK
PHONE#: 612-210-6971
DRAWN BY: SHANNON MROZEK
DESIGN DATE: 08/10/2024

Revised Print
 Destroy All Others
 Revision History
 Date:
 Description:
 Design Approval: