

9887 Lawndale Ln N, Maple Grove
1 ph. UG extension, LBC & TR.

WO # 112832759
Sketch 1/1
Access: Truck
Feeder: ECK341

Rush Creek Blvd

Lawndale Ln N

50B

9887

9885

P2

S1

P2

65SM-20

P1

Garland Ln
N/98th Way N

P1: Splice into existing 1/0AL 35kV, 3 phase primary cable. 1 phase splice on "B" phase. Splice out two ~10' - 20' loop in new fused 1 phase LBC.

P2: Set new fused 1 phase LBC, B phase.
POI: K52011W03
Fuse POI: K52011F15

P3: Set new 1ph 50kva, 120/240 volt 19.9kVa transformer for signal & lighting services.
Terminate services.
POI: K52001T16

S1: Bore in new 1 phase 1/0 AL cable from new LBC (P2) to new transformer (P3); ~800' along west side of Lawndale Ln N.



Adam Barthel
C: 612-368-6427

Work Order Information

Service Request # : 000014786053
Design Number : 000001186931
Designer/Planner ID : 248845
Designer/Planner Name :
Designer/Planner Ph # :
Manager Approval :

Joint Utility

E: G:
T: C:

Design Location

Division : Maple Grove
County : Hennepin
City : Maple Grove
Address :
T: 119N R: 22W S: 7
Map # : K52001 Permit :

Electric

Feeder: Voltage:
Phase: Bkup Dev ID:

Gas


System : Pressure :
Size : Material :
Dead End :

Work Order # :

Date: 09/05/2024

Sketch:

Scale: 1" equals 86'



CONSTRUCTION USE ONLY

- NO CHANGES (BUILT AS DESIGNED)
- CHANGES MADE AS INDICATED
(ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE)

RFO

FOREMAN _____ DATE _____

TEAM LEADER _____