


**9371 RANCHVIEW LN N MAPLE GROVE, MN**  
 WO: 113068835  
 UG CONSTRUCTION

UG FAULT. INSTALL NEW SECONDARY CABLE AND CONDUIT BY BORE.

INSTALL:  
 80' #6 DUPLEX SECONDARY CABLE  
 80' 1 1/2 CONDUIT

ABANDON:  
 80' SECONDARY CABLE

RESTORATION  
 MATERIALS: MAPLE GROVE  
 CABLE & CONDUIT: MAPLE GROVE



| Work Order Information |                |
|------------------------|----------------|
| Service Request #      | : 000014938729 |
| Design Number          | : 000001193892 |
| Designer/Planner ID    | : 322005       |
| Designer/Planner Name  | :              |
| Designer/Planner Ph #  | : 651-627-2962 |
| Manager Approval       | :              |


| Joint Utility |    |
|---------------|----|
| E:            | G: |
| T:            | C: |

| Design Location |                   |
|-----------------|-------------------|
| Division        | : Maple Grove     |
| County          | : Hennepin        |
| City            | : Maple Grove     |
| Address         | :                 |
| T: 119N         | R: 22W S: 9       |
| Map #           | : K52024 Permit : |

| Electric |              |
|----------|--------------|
| Feeder:  | Voltage:     |
| Phase:   | Bkup Dev ID: |

| Gas      |              |
|----------|--------------|
| System   | : Pressure : |
| Size     | : Material : |
| Dead End | :            |

Work Order # :  
 Date: 10/28/2024  
 Sketch: #1 Of #1 Sketch Data  
 Scale: 1" equals 63'



**CONSTRUCTION USE ONLY**

NO CHANGES (BUILT AS DESIGNED)  
 CHANGES MADE AS INDICATED  
 (ALL URD MUST HAVE ACTUAL MEASUREMENTS FROM THE FIELD SITE)

RFO \_\_\_\_\_  
 FOREMAN \_\_\_\_\_ DATE \_\_\_\_\_  
 TEAM LEADER \_\_\_\_\_

DISCLAIMER: THERE ARE NO REPRESENTATIONS OR WARRANTIES (EXPRESS OR IMPLIED) ABOUT THE ACCURACY OF THIS PRINT. THIS PRINT IS PROVIDED WITH NO CLAIM AS TO PRINT COMPLETENESS, TIMELINESS, ACCURACY OF CONTENT OR USEFULNESS. STATE LAW REQUIRES ANYONE DIGGING, GRADING OR EXCAVATING TO OBTAIN A PRIOR FIELD LOCATE OF ALL UTILITIES; THIS PRINT DOES NOT DISCHARGE THIS REQUIREMENT OR ANY OTHER REQUIREMENT. THE COMPANY AND ITS AFFILIATES ASSUME NO LEGAL RESPONSIBILITY OR LIABILITY FOR THE RECIPIENT'S USE (OR ANY OTHER PARTIES' USE) OF THE PRINT, INCLUDING THE RECIPIENTS INTENDED PURPOSE IN USING THE PRINT. NO COMPANY EMPLOYEE OR OTHER PARTY HAS BEEN AUTHORIZED TO PROVIDE THIS PRINT FOR PLANNING OR ESTIMATING PURPOSES; RELY ON THIS PRINT AT YOUR OWN RISK. BY ACCEPTING THIS PRINT, THE RECIPIENT & ANY OTHER PARTY RECEIVING A COPY OF THE PRINT ACKNOWLEDGES AND AGREES TO THIS DISCLAIMER. For All Field Locates Call 811

THIS DOCUMENT IS XCEL ENERGY CONFIDENTIALS AND PROPRIETARY INFORMATION AND MAY NOT BE REPRODUCED IN WHOLE, OR IN PART, NOR MAY ANY OF THE INFORMATION CONTAINED HEREIN BE DISCLOSED WITHOUT THE CONSENT OF XCEL ENERGY. CONFIDENTIALS AND PROPRIETARY INFORMATION © 2019 XCEL ENERGY INC. | XCEL ENERGY IS REGISTERED TRADEMARK OF XCEL ENERGY INC